

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081902

Port Orford-Langlois 2CJ School Distict	Project: General	Date Reported: 08/30/16
PO Box 8	Project #: Driftwood Elem & Pacific High	Date Received: 08/16/16 09:30
Port Orford, OR 97465	School	Sampled By: Steve Perkins
	Client Contact: Attn: Steve Perkins	

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6081902-01	Sample Location: #1/Kitchen Sink									
Lead		1030	0.012	mg/L	0.002	0.02	08/11/16 09:40	08/24/16	DJP	
Copper			6.029	mg/L	0.010	1.3	08/11/16 09:40	08/25/16	DJP	CON-1
6081902-02	Sample Location: #2/Kitchen Rinse Bath									
Lead		1030	0.008	mg/L	0.002	0.02	08/11/16 09:41	08/24/16	DJP	
Copper			0.090	mg/L	0.010	1.3	08/11/16 09:41	08/24/16	DJP	
6081902-03	Sample Location: #3/Office Sink									
Lead		1030	0.008	mg/L	0.002	0.02	08/11/16 09:44	08/24/16	DJP	
Copper			0.491	mg/L	0.010	1.3	08/11/16 09:44	08/24/16	DJP	
6081902-04	Sample Location: #4/Staff Room Sink									
Lead		1030	0.013	mg/L	0.002	0.02	08/11/16 09:45	08/24/16	DJP	
Copper			0.100	mg/L	0.010	1.3	08/11/16 09:45	08/24/16	DJP	
6081902-05	Sample Location: #5/Staff Bathroom									
Lead		1030	ND	mg/L	0.002	0.02	08/11/16 09:46	08/24/16	DJP	
Copper			0.170	mg/L	0.010	1.3	08/11/16 09:46	08/24/16	DJP	
6081902-06	Sample Location: #6/Fountain Near Office									
Lead		1030	0.013	mg/L	0.002	0.02	08/11/16 09:50	08/24/16	DJP	
Copper			0.482	mg/L	0.010	1.3	08/11/16 09:50	08/24/16	DJP	
6081902-07	Sample Location: #7/Girls Bathroom in Main Hall									
Lead		1030	0.005	mg/L	0.002	0.02	08/11/16 09:51	08/24/16	DJP	
Copper			0.080	mg/L	0.010	1.3	08/11/16 09:51	08/24/16	DJP	
6081902-08	Sample Location: #8/1st Sink (Left) in Boy's BR in Main Hall									
Lead		1030	ND	mg/L	0.002	0.02	08/11/16 09:52	08/24/16	DJP	
Copper			0.144	mg/L	0.010	1.3	08/11/16 09:52	08/24/16	DJP	
6081902-09	Sample Location: #9/2nd Sink (Right) in Boy's BR in Main Hall									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081902

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.020	mg/L	0.002	0.02	08/11/16 09:53	08/25/16	DJP	CON-1
Copper			0.317	mg/L	0.010	1.3	08/11/16 09:53	08/25/16	DJP	
6081902-10	Sample Location: #10/Sink in Room 3									
Lead		1030	0.004	mg/L	0.002	0.02	08/11/16 09:54	08/24/16	DJP	
Copper			0.023	mg/L	0.010	1.3	08/11/16 09:54	08/24/16	DJP	
6081902-11	Sample Location: #11/Sink in Room 4									
Lead		1030	ND	mg/L	0.002	0.02	08/11/16 09:55	08/24/16	DJP	
Copper			0.020	mg/L	0.010	1.3	08/11/16 09:55	08/24/16	DJP	
6081902-12	Sample Location: #12/Sink in Room 5									
Lead		1030	ND	mg/L	0.002	0.02	08/11/16 09:56	08/24/16	DJP	
Copper			2.104	mg/L	0.010	1.3	08/11/16 09:56	08/25/16	DJP	CON-1
6081902-13	Sample Location: #13/Fountain in Room 5									
Lead		1030	0.005	mg/L	0.002	0.02	08/11/16 09:57	08/24/16	DJP	
Copper			2.999	mg/L	0.010	1.3	08/11/16 09:57	08/25/16	DJP	CON-1
6081902-14	Sample Location: #14/Sink in Room 6									
Lead		1030	0.016	mg/L	0.002	0.02	08/11/16 09:58	08/24/16	DJP	
Copper			1.684	mg/L	0.010	1.3	08/11/16 09:58	08/25/16	DJP	CON-1
6081902-15	Sample Location: #15/Fountain in Room 6									
Lead		1030	0.009	mg/L	0.002	0.02	08/11/16 09:59	08/24/16	DJP	
Copper			2.325	mg/L	0.010	1.3	08/11/16 09:59	08/25/16	DJP	CON-1
6081902-16	Sample Location: #16/Sink in Room 7									
Lead		1030	0.002	mg/L	0.002	0.02	08/11/16 10:00	08/24/16	DJP	
Copper			0.016	mg/L	0.010	1.3	08/11/16 10:00	08/24/16	DJP	
6081902-17	Sample Location: #17/Sink in Room 8									
Lead		1030	0.014	mg/L	0.002	0.02	08/11/16 10:02	08/24/16	DJP	
Copper			0.766	mg/L	0.010	1.3	08/11/16 10:02	08/24/16	DJP	
6081902-18	Sample Location: #18/Sink in Room 9									
Lead		1030	0.007	mg/L	0.002	0.02	08/11/16 10:03	08/24/16	DJP	
Copper			0.290	mg/L	0.010	1.3	08/11/16 10:03	08/24/16	DJP	
6081902-19	Sample Location: #19/Fountain in Room 9									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager

**UMPQUA Research Company**

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT**URC # 6081902****Method: EPA 200.8**

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.006	mg/L	0.002	0.02	08/11/16 10:03	08/24/16	DJP	
Copper			0.020	mg/L	0.010	1.3	08/11/16 10:03	08/24/16	DJP	
6081902-20	Sample Location: #20/Sink in Room 10									
Lead		1030	ND	mg/L	0.002	0.02	08/11/16 10:04	08/24/16	DJP	
Copper			0.426	mg/L	0.010	1.3	08/11/16 10:04	08/24/16	DJP	
6081902-21	Sample Location: #21/Fountain in Room 10									
Lead		1030	0.004	mg/L	0.002	0.02	08/11/16 10:04	08/24/16	DJP	
Copper			0.564	mg/L	0.010	1.3	08/11/16 10:04	08/24/16	DJP	
6081902-22	Sample Location: #22/Sink in Room 11									
Lead		1030	0.006	mg/L	0.002	0.02	08/11/16 10:07	08/24/16	DJP	
Copper			0.431	mg/L	0.010	1.3	08/11/16 10:07	08/24/16	DJP	
6081902-23	Sample Location: #23/Fountain in Room 11									
Lead		1030	0.007	mg/L	0.002	0.02	08/11/16 10:09	08/24/16	DJP	
Copper			0.663	mg/L	0.010	1.3	08/11/16 10:09	08/24/16	DJP	
6081902-24	Sample Location: #24/Girl's BR in Computer Lab Wing									
Lead		1030	0.019	mg/L	0.002	0.02	08/11/16 10:10	08/24/16	DJP	
Copper			0.360	mg/L	0.010	1.3	08/11/16 10:10	08/24/16	DJP	
6081902-25	Sample Location: #25/1st Sink (Left) in Boy's BR in Computer Lab Wing									
Lead		1030	ND	mg/L	0.002	0.02	08/11/16 10:11	08/24/16	DJP	
Copper			0.083	mg/L	0.010	1.3	08/11/16 10:11	08/24/16	DJP	
6081902-26	Sample Location: #27/Sink in Room 12									
Lead		1030	0.004	mg/L	0.002	0.02	08/11/16 10:15	08/24/16	DJP	
Copper			0.431	mg/L	0.010	1.3	08/11/16 10:15	08/24/16	DJP	
6081902-27	Sample Location: #28/Fountain in Room 12									
Lead		1030	0.003	mg/L	0.002	0.02	08/11/16 10:16	08/24/16	DJP	
Copper			0.776	mg/L	0.010	1.3	08/11/16 10:16	08/24/16	DJP	
6081902-28	Sample Location: #29/Sink in Room 13									
Lead		1030	ND	mg/L	0.002	0.02	08/11/16 10:20	08/24/16	DJP	
Copper			0.366	mg/L	0.010	1.3	08/11/16 10:20	08/24/16	DJP	
6081902-29	Sample Location: #30/Fountain in Room 13									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081902

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.003	mg/L	0.002	0.02	08/11/16 10:20	08/24/16	DJP	
Copper			0.532	mg/L	0.010	1.3	08/11/16 10:20	08/24/16	DJP	
6081902-30	Sample Location: #31/Fountain Near Pop Machine									
Lead		1030	0.009	mg/L	0.002	0.02	08/11/16 11:54	08/24/16	DJP	
Copper			0.190	mg/L	0.010	1.3	08/11/16 11:54	08/24/16	DJP	
6081902-31	Sample Location: #32/1st Fountain Nearest to Lib. in Library wing									
Lead		1030	0.004	mg/L	0.002	0.02	08/11/16 11:55	08/24/16	DJP	
Copper			0.336	mg/L	0.010	1.3	08/11/16 11:55	08/24/16	DJP	
6081902-32	Sample Location: #33/2nd Fountain Furthest from Lib. in Library wing									
Lead		1030	0.011	mg/L	0.002	0.02	08/11/16 11:56	08/24/16	DJP	
Copper			0.434	mg/L	0.010	1.3	08/11/16 11:56	08/24/16	DJP	
6081902-33	Sample Location: #34/Science Lab Sink									
Lead		1030	0.012	mg/L	0.002	0.02	08/11/16 11:58	08/24/16	DJP	
Copper			0.184	mg/L	0.010	1.3	08/11/16 11:58	08/24/16	DJP	
6081902-34	Sample Location: #35/Science Lab Station 1, Left Faucet									
Lead		1030	0.218	mg/L	0.002	0.02	08/11/16 11:58	08/25/16	DJP	CON-1
Copper			0.249	mg/L	0.010	1.3	08/11/16 11:58	08/25/16	DJP	
6081902-35	Sample Location: #36/Science Lab Station 1, Right Faucet									
Lead		1030	0.151	mg/L	0.002	0.02	08/11/16 11:59	08/25/16	DJP	CON-1
Copper			0.223	mg/L	0.010	1.3	08/11/16 11:59	08/25/16	DJP	
6081902-36	Sample Location: #37/Science Lab Station 2, Left Faucet									
Lead		1030	0.287	mg/L	0.002	0.02	08/11/16 11:59	08/25/16	DJP	CON-1
Copper			0.204	mg/L	0.010	1.3	08/11/16 11:59	08/25/16	DJP	
6081902-37	Sample Location: #38/Science Lab Station 2, Right Faucet									
Lead		1030	0.018	mg/L	0.002	0.02	08/11/16 11:59	08/24/16	DJP	
Copper			0.218	mg/L	0.010	1.3	08/11/16 11:59	08/24/16	DJP	
6081902-38	Sample Location: #39/Science Lab Station 3, Left Faucet									
Lead		1030	0.444	mg/L	0.002	0.02	08/11/16 12:00	08/25/16	DJP	CON-1
Copper			0.179	mg/L	0.010	1.3	08/11/16 12:00	08/25/16	DJP	
6081902-39	Sample Location: #40/Science Lab Station 3, Right Faucet									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081902

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.650	mg/L	0.002	0.02	08/11/16 12:00	08/25/16	DJP	CON-1
Copper			0.181	mg/L	0.010	1.3	08/11/16 12:00	08/25/16	DJP	
6081902-40	Sample Location: #41/Wellness Center Main Sink									
Lead		1030	0.035	mg/L	0.002	0.02	08/11/16 12:02	08/25/16	DJP	CON-1
Copper			0.134	mg/L	0.010	1.3	08/11/16 12:02	08/25/16	DJP	
6081902-41	Sample Location: #42/Wellness Center Bathroom Sink									
Lead		1030	ND	mg/L	0.002	0.02	08/11/16 12:02	08/24/16	DJP	
Copper			0.078	mg/L	0.010	1.3	08/11/16 12:02	08/24/16	DJP	
6081902-42	Sample Location: #43/Wellness Center Observation Room Sink									
Lead		1030	0.005	mg/L	0.002	0.02	08/11/16 12:03	08/24/16	DJP	
Copper			0.049	mg/L	0.010	1.3	08/11/16 12:03	08/24/16	DJP	
6081902-43	Sample Location: #44/1st Sink in Staff Room									
Lead		1030	0.008	mg/L	0.002	0.02	08/11/16 12:05	08/24/16	DJP	
Copper			0.170	mg/L	0.010	1.3	08/11/16 12:05	08/24/16	DJP	
6081902-44	Sample Location: #45/2nd Sink in Staff Room									
Lead		1030	0.014	mg/L	0.002	0.02	08/11/16 12:05	08/24/16	DJP	
Copper			0.287	mg/L	0.010	1.3	08/11/16 12:05	08/24/16	DJP	
6081902-45	Sample Location: #46/1st Sink (Right) in Girl's BR Nearest the Office									
Lead		1030	0.008	mg/L	0.002	0.02	08/11/16 12:07	08/24/16	DJP	
Copper			0.143	mg/L	0.010	1.3	08/11/16 12:07	08/24/16	DJP	
6081902-46	Sample Location: #47/2nd Sink (Left) in Girl's BR Nearest the Office									
Lead		1030	0.004	mg/L	0.002	0.02	08/11/16 12:07	08/24/16	DJP	
Copper			0.155	mg/L	0.010	1.3	08/11/16 12:07	08/24/16	DJP	
6081902-47	Sample Location: #48/Left Sink in Boy's BR Nearest the Office									
Lead		1030	0.016	mg/L	0.002	0.02	08/11/16 12:09	08/24/16	DJP	
Copper			0.257	mg/L	0.010	1.3	08/11/16 12:09	08/24/16	DJP	
6081902-48	Sample Location: #49/Right Sink in Boy's BR Nearest the Office									
Lead		1030	0.009	mg/L	0.002	0.02	08/11/16 12:09	08/24/16	DJP	
Copper			0.184	mg/L	0.010	1.3	08/11/16 12:09	08/24/16	DJP	
6081902-49	Sample Location: #50/Sink in Unisex Bathroom									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081902

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
	Lead	1030	ND	mg/L	0.002	0.02	08/11/16 12:10	08/24/16	DJP	
	Copper		0.232	mg/L	0.010	1.3	08/11/16 12:10	08/24/16	DJP	
6081902-50	Sample Location: #51/Left Sink in Girl's BR Nearest the Music Room									
	Lead	1030	0.029	mg/L	0.002	0.02	08/11/16 12:12	08/25/16	DJP	CON-1
	Copper		0.266	mg/L	0.010	1.3	08/11/16 12:12	08/25/16	DJP	
6081902-51	Sample Location: #52/Right Sink in Girl's BR Nearest the Music Room									
	Lead	1030	0.028	mg/L	0.002	0.02	08/11/16 12:12	08/25/16	DJP	CON-1
	Copper		0.380	mg/L	0.010	1.3	08/11/16 12:12	08/25/16	DJP	
6081902-52	Sample Location: #53/Left Sink in Boy's BR Nearest the Music Room									
	Lead	1030	0.029	mg/L	0.002	0.02	08/11/16 12:13	08/24/16	DJP	CON-1
	Copper		0.283	mg/L	0.010	1.3	08/11/16 12:13	08/24/16	DJP	
6081902-53	Sample Location: #54/Right Sink in Boy's BR Nearest the Music Room									
	Lead	1030	0.024	mg/L	0.002	0.02	08/11/16 12:13	08/25/16	DJP	CON-1
	Copper		0.277	mg/L	0.010	1.3	08/11/16 12:13	08/25/16	DJP	
6081902-54	Sample Location: #55/Drinking Fountain Nearest the Music Room									
	Lead	1030	ND	mg/L	0.002	0.02	08/11/16 12:14	08/24/16	DJP	
	Copper		0.789	mg/L	0.010	1.3	08/11/16 12:14	08/24/16	DJP	
6081902-55	Sample Location: #56/Sink in Room 8									
	Lead	1030	0.036	mg/L	0.002	0.02	08/11/16 12:23	08/25/16	DJP	CON-1
	Copper		0.137	mg/L	0.010	1.3	08/11/16 12:23	08/25/16	DJP	
6081902-56	Sample Location: #57/Sink in Cafeteria									
	Lead	1030	0.021	mg/L	0.002	0.02	08/11/16 12:24	08/25/16	DJP	CON-1
	Copper		0.424	mg/L	0.010	1.3	08/11/16 12:24	08/25/16	DJP	
6081902-57	Sample Location: #58/Wash Basin in Cafeteria									
	Lead	1030	0.002	mg/L	0.002	0.02	08/11/16 12:24	08/24/16	DJP	
	Copper		0.025	mg/L	0.010	1.3	08/11/16 12:24	08/24/16	DJP	
6081902-58	Sample Location: #59/Sink in Music Room									
	Lead	1030	0.009	mg/L	0.002	0.02	08/11/16 12:26	08/24/16	DJP	
	Copper		0.100	mg/L	0.010	1.3	08/11/16 12:26	08/24/16	DJP	
6081902-59	Sample Location: #60/Sink in Boy's Locker Room									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081902

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
	Lead	1030	0.003	mg/L	0.002	0.02	08/11/16 12:27	08/24/16	DJP	
	Copper		0.099	mg/L	0.010	1.3	08/11/16 12:27	08/24/16	DJP	
6081902-60	Sample Location: #61/Fountain in Boy's Locker Room									
	Lead	1030	0.003	mg/L	0.002	0.02	08/11/16 12:30	08/24/16	DJP	
	Copper		0.063	mg/L	0.010	1.3	08/11/16 12:30	08/24/16	DJP	
6081902-61	Sample Location: #62/Fountain in Gym									
	Lead	1030	0.006	mg/L	0.002	0.02	08/11/16 12:31	08/24/16	DJP	
	Copper		0.175	mg/L	0.010	1.3	08/11/16 12:31	08/24/16	DJP	
6081902-62	Sample Location: #63/Sink in Coaches Room Boy's Locker Room									
	Lead	1030	0.041	mg/L	0.002	0.02	08/11/16 12:32	08/24/16	DJP	CON-1
	Copper		0.370	mg/L	0.010	1.3	08/11/16 12:32	08/24/16	DJP	
6081902-63	Sample Location: #64/Sink in Girl's Locker Room									
	Lead	1030	0.005	mg/L	0.002	0.02	08/11/16 12:33	08/24/16	DJP	
	Copper		0.133	mg/L	0.010	1.3	08/11/16 12:33	08/24/16	DJP	
6081902-64	Sample Location: #65/Fountain in Girl's Locker Room									
	Lead	1030	0.014	mg/L	0.002	0.02	08/11/16 12:33	08/24/16	DJP	
	Copper		0.121	mg/L	0.010	1.3	08/11/16 12:33	08/24/16	DJP	
6081902-65	Sample Location: #66/Sink in Referee's Room Girl's End									
	Lead	1030	0.009	mg/L	0.002	0.02	08/11/16 12:36	08/24/16	DJP	
	Copper		0.130	mg/L	0.010	1.3	08/11/16 12:36	08/24/16	DJP	
6081902-66	Sample Location: #67/1st Sink in Art Room									
	Lead	1030	0.029	mg/L	0.002	0.02	08/11/16 12:43	08/25/16	DJP	CON-1
	Copper		0.240	mg/L	0.010	1.3	08/11/16 12:43	08/25/16	DJP	
6081902-67	Sample Location: #68/Middle Sink in Art Room									
	Lead	1030	0.007	mg/L	0.002	0.02	08/11/16 12:43	08/24/16	DJP	
	Copper		0.161	mg/L	0.010	1.3	08/11/16 12:43	08/24/16	DJP	
6081902-68	Sample Location: #69/3rd Sink in Art Room									
	Lead	1030	0.008	mg/L	0.002	0.02	08/11/16 12:43	08/24/16	DJP	
	Copper		0.096	mg/L	0.010	1.3	08/11/16 12:43	08/24/16	DJP	
6081902-69	Sample Location: #70/Sink in Welding Room									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081902

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.006	mg/L	0.002	0.02	08/11/16 12:44	08/24/16	DJP	
Copper			0.330	mg/L	0.010	1.3	08/11/16 12:44	08/24/16	DJP	
6081902-70	Sample Location: #71/Sink in Wood's Room									
Lead		1030	0.004	mg/L	0.002	0.02	08/11/16 12:46	08/24/16	DJP	
Copper			0.138	mg/L	0.010	1.3	08/11/16 12:46	08/24/16	DJP	
6081902-71	Sample Location: #72/Sink in AD Room									
Lead		1030	0.092	mg/L	0.002	0.02	08/11/16 12:51	08/25/16	DJP	CON-1
Copper			1.270	mg/L	0.010	1.3	08/11/16 12:51	08/25/16	DJP	
6081902-72	Sample Location: #73/Fountain in Music Room									
Lead		1030	0.009	mg/L	0.002	0.02	08/11/16 12:52	08/24/16	DJP	
Copper			0.067	mg/L	0.010	1.3	08/11/16 12:52	08/24/16	DJP	
6081902-73	Sample Location: #74/Sink in Concession Room									
Lead		1030	0.059	mg/L	0.002	0.02	08/11/16 12:54	08/25/16	DJP	CON-1
Copper			0.444	mg/L	0.010	1.3	08/11/16 12:54	08/25/16	DJP	
6081902-74	Sample Location: #75/Girl's BR Sink at Field									
Lead		1030	0.015	mg/L	0.002	0.02	08/11/16 13:34	08/24/16	DJP	
Copper			0.674	mg/L	0.010	1.3	08/11/16 13:34	08/24/16	DJP	
6081902-75	Sample Location: #76/Boy's BR Sink at Field									
Lead		1030	0.014	mg/L	0.002	0.02	08/11/16 13:38	08/24/16	DJP	
Copper			0.760	mg/L	0.010	1.3	08/11/16 13:38	08/24/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081902

Qualifiers and Definitions

QM-4X	The spike recovery was outside of QC acceptance limits for the MS and/or MSD due to analyte concentration at 4 times or greater the spike concentration. The QC batch was accepted based on LCS/SRM recovery within the acceptance limits.
CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.